


7/16" HOLES 1-1/4" FROM OUTSIDE EDGE ARE PROVIDED ALONG PERIMETER (24" MIN. O.C.) OF FLANGE FOR MOUNTING.



ORDER WILL NOT BE RELEASED FOR FABRICATION UNTIL SIGNED COPY IS RECEIVED.

VERIFICATION AND APPROVAL OF GENERAL ARRANGEMENT AND OVERALL DIMENSIONS OF THIS DOCUMENT ARE REQUIRED BEFORE THE ORDER IS ENTERED FOR MANUFACTURING.

APPROVAL SIGNATURE _____
 TITLE HELD _____
 DATE OF APPROVAL _____

U-LP "LOW PROFILE" HEAT & SMOKE VENT			
MATERIAL SCHEDULE			
QUANTITY	SIZE	COVER	FRAME

MODEL NUMBER	INSIDE CURB DIM. WIDTH X LENGTH	QTY.	UL	FM
U-LP-4848	48" X 48"		✓	✓
U-LP-4860	48" X 60"		✓	✓
U-LP-4872	48" X 72"		✓	✓
U-LP-4884	48" X 84"		✓	✓
U-LP-4890	48" X 90"		✓	✓
U-LP-4896	48" X 96"		✓	✓
U-LP-5448	54" X 48"		✓	✓
U-LP-5460	54" X 60"		✓	✓
U-LP-5472	54" X 72"		✓	✓

MILCO

GALVANIZED STEEL CONSTRUCTION

DEALER _____
 PROJECT _____
 LOCATION _____
 ARCH. _____
 DATE _____ DRAWN _____
 _____ JOB NO. _____
 REV:(A) UP LIFT PRESSURE WAS 30 PSF(03/17/10)
 SHEET

NOTES:

- * LISTED BY UNDERWRITERS' LABORATORIES
- * APPROVED BY FACTORY MUTUAL (SNOW RATE 10 PSF)
- * APPROVED BY FACTORY MUTUAL (UP-LIFT PRESSURE 240 PSF)
- * CURB WIDTHS X LENGTHS BETWEEN THE STANDARD LISTED SIZES ARE CUSTOM.